



# Clovis Fire Department

## Standard # 2.2

### FDC & PIV ADDRESS IDENTIFICATION

The Clovis Fire Department has adopted the following standard that identifies the Fire Department Connection (FDC) and the Post Indicator Valve (PIV) for each fire sprinkler system located in the City of Clovis. The Fire Department must be able to easily identify the location of the appropriate FDC & PIV when a fire occurs.

All Fire Department Connections and Post Indicator Valves shall be identified as follows:

1. They shall be painted **RED**. No paint shall be used around the swivel connections.
2. Two inch (2") minimum **WHITE** address numbers shall be stenciled vertically with the numbers located as close to the top as possible. The numbers must be able to be seen from the adjacent driveway or roadway. (CFC 2013 912.2.1)
3. If they serve more than one address, the numbers must be installed with the smaller number located at the top, separated with the word "TO" and the larger address number on the bottom. If they do not have room for the address in the vertical position, it can be placed on a horizontal sign and U-bolted to the riser pipe.
4. Fire Department Connection shall be a minimum of eighteen inches (18") from the center of orifice to the ground.

The above requirements must be installed and approved prior to the final inspection on the fire sprinkler system.



**Fire  
Department  
Connection**



**Post  
Indicator  
Valve**