



# Clovis Fire Department

## Standard # 16

### CHRISTMAS TREE LOT REQUIREMENTS

1. No open fires allowed. No burn barrels.
2. Temporary structures used for flocking and applying fire retardant may be covered in the slow-burning type plastic provided one side of the structure has an opening no less than eight feet (8') wide and eight feet (8') tall.
3. All electric lights and electrical circuits must be installed and approved by the Clovis City Building Department.
4. All electric lights must be placed no less than twelve inches (12") from plastic material.
5. Space heaters must be listed and be kept a minimum of three feet (3') from any combustible material.
6. The Public shall not be allowed in any temporary structures.
7. All tree lots must have one 2A-10BC dry chemical fire extinguisher on site.
8. All Christmas trees sold for commercial use must be fire retardant treated with a listed, approved chemical by an approved, State-licensed operator when sold to a business located in the City of Clovis.
9. The State-licensed fire retardant applicator must have his license on display on site, plus demonstrate knowledge, when asked, regarding the chemical being applied.